

Customer

Mark Corrigan
RainSafe Water
Block 2
Newtown Business & Enterprise
Newtownmountkennedy
Co Wicklow

Certificate Of Analysis

Job Number: 17-25767
Issue Number: 1
Report Date: 24 February 2017

Site: Not Applicable
PO Number: MARK CORRIGAN
Date Samples Received: 07/02/2017

Please find attached the results for the samples received at our laboratory on 07/02/2017.

Should you have any queries regarding the report or require any further services, we would be happy to discuss your requirements. For additional information about the company please log-on to our website at the above address.

Thank you for choosing City Analysts Limited. We look forward to assisting you again.

Authorised By:



Shane Reynolds
Laboratory Manager

Authorised Date: 24 February 2017

Notes:

Results relate only to the items tested.
Information on methods of analysis and performance characteristics is available on request.
Any opinions or interpretations indicated are outside the scope of our INAB accreditation.
This test report shall not be reproduced except in full or with written approval of City Analysts Limited.

Certificate Of Analysis

Customer

Mark Corrigan
RainSafe Water
Block 2
Newtown Business & Enterprise
Newtownmountkennedy
Co Wicklow

Report Reference: 17-25767

Report Version: 1

Site: Not Applicable
Sample Description: Before sample A
Sample Type: Treated
Lab Reference Number: 347927

Date of Sampling: 07/02/2017
Time of Sampling: 10:30
Date Sample Received: 07/02/2017

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
D/	08/02/2017	Miscellaneous Testing	See report attached	N/A	-
D/	08/02/2017	Miscellaneous Testing	See report attached	N/A	-
Legionella					
S/S3232#	08/02/2017	L. pneumophila Sgp 2-14	Not Detected	N/A	-
S/S3232#	08/02/2017	L. pneumophila Sgp 1	Not Detected	N/A	-
S/S3232#	08/02/2017	Legionella spp	Not Detected	N/A	-
S/S3232#	08/02/2017	Legionella	< 1	cfu/l	-

= INAB Accredited, U = UKAS Accredited, * = Subcontracted

Note:

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon

Certificate Of Analysis

Customer

Mark Corrigan
RainSafe Water
Block 2
Newtown Business & Enterprise
Newtownmountkennedy
Co Wicklow

Report Reference: 17-25767

Report Version: 1

Site: Not Applicable

Sample Description: Before sample B

Date of Sampling: 07/02/2017

Sample Type: Treated

Time of Sampling: 10:30

Lab Reference Number: 347928

Date Sample Received: 07/02/2017

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
Legionella					
S/S3232#	08/02/2017	L. pneumophila Sgp 2-14	Not Detected	N/A	-
S/S3232#	08/02/2017	L. pneumophila Sgp 1	Detected	N/A	-
S/S3232#	08/02/2017	Legionella spp	Not Detected	N/A	-
S/S3232#	08/02/2017	Legionella	120	cfu/l	-

= INAB Accredited, U = UKAS Accredited, * = Subcontracted

Note:

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon

Certificate Of Analysis

Customer

Mark Corrigan
RainSafe Water
Block 2
Newtown Business & Enterprise
Newtownmountkennedy
Co Wicklow

Report Reference: 17-25767

Report Version: 1

Site: Not Applicable

Sample Description: After sample A

Date of Sampling: 07/02/2017

Sample Type: Treated

Time of Sampling: 10:30

Lab Reference Number: 347929

Date Sample Received: 07/02/2017

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
Legionella					
S/S3232#	08/02/2017	L. pneumophila Sgp 2-14	Not Detected	N/A	-
S/S3232#	08/02/2017	L. pneumophila Sgp 1	Not Detected	N/A	-
S/S3232#	08/02/2017	Legionella spp	Not Detected	N/A	-
S/S3232#	08/02/2017	Legionella	< 1	cfu/l	-

= INAB Accredited, U = UKAS Accredited, * = Subcontracted

Note:

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon

Certificate Of Analysis

Customer

Mark Corrigan
RainSafe Water
Block 2
Newtown Business & Enterprise
Newtownmountkennedy
Co Wicklow

Report Reference: 17-25767

Report Version: 1

Site: Not Applicable
Sample Description: After sample B
Sample Type: Treated
Lab Reference Number: 347930

Date of Sampling: 07/02/2017
Time of Sampling: 10:30
Date Sample Received: 07/02/2017

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
Legionella					
S/S3232#	08/02/2017	L. pneumophila Sgp 2-14	Not Detected	N/A	-
S/S3232#	08/02/2017	L. pneumophila Sgp 1	Not Detected	N/A	-
S/S3232#	08/02/2017	Legionella spp	Not Detected	N/A	-
S/S3232#	08/02/2017	Legionella	< 1	cfu/l	-

= INAB Accredited, U = UKAS Accredited, * = Subcontracted

Note:

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon